

	Legal limits of the European bathing water directive		Effluent of reed bed treatment system for bathing water in the city of Göttingen
Escherichia Coli	100	Cfu/100ml	< 15
Pseudomonas aeruginosa	10	cfu/100ml	0
Enterococci	50	cfu/100ml	< 15
pH	6 - 9		7,7
Total Phosphorus		mg/l	< 0,2
water transparency / turbidity	>1	m	> 1,2